

# **2017 Annual Drinking Water Quality Report**

## **HCSA – Leigh Street Plant PWSID NO. 5780600**

### **INTRODUCTION**

This Annual Drinking Water Quality Report for calendar year 2017 is designed to inform you about your drinking water quality. Our goal is to provide you with a safe and dependable supply of drinking water, and we want you to understand the efforts we make to protect your water supply. The quality of your drinking water must meet state and federal requirements administered by the Virginia Department of Health (VDH).

If you have questions about this report, or if you want additional information about any aspect of your drinking water or want to know how to participate in decisions that may affect the quality of your drinking water, please contact: William Samples, Superintendent of Water at 434-575-4255

### **GENERAL INFORMATION**

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

All drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Halifax County Service Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential lead exposure by flushing your tap for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## **SOURCE OF YOUR DRINKING WATER**

The source of your drinking water is surface water with the raw water intake located in the Dan River. Treatment of the raw water consists of chemical addition, coagulation, flocculation, settling, filtration, fluoridation and chlorination. All of these processes work together to remove the physical, chemical, and biological contaminants to make the water safe for drinking.

A source water assessment of our system was conducted in 2002 by the Virginia Department of Health. The Dan River was determined to be of high susceptibility to contamination using the criteria developed by the state in its approved Source Water Assessment Program. The assessment report consists of maps showing the source water assessment area, an inventory of known land use activities of concern, and documentation of any known contamination within the last 5 years. The report is available by contacting your water system representative at the phone number or address given elsewhere in this drinking water quality report.

## **DEFINITIONS**

Contaminants in your drinking water are routinely monitored according to Federal and State regulations. The table on the next page shows the results of our monitoring for calendar year 2017. In the table and elsewhere in this report you will find many terms and abbreviations you might not be familiar with. The following definitions are provided to help you better understand these terms:

*Non-detects (ND)* - lab analysis indicates that the contaminant is not present within the detection limits of the instrument used.

*Parts per billion (ppb) or Micrograms per liter (Hg/l)* - one part per billion corresponds to one minute in 2,000 years, or one penny in \$10,000,000.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or one penny in \$ 10,000.

*Picocuries per liter (pCi/L)* - picocuries per liter is a measure of the radioactivity in water.

*Nephelometric Turbidity Unit (NTU)* - nephelometric turbidity unit is a measure of the cloudiness of the water. Turbidity in excess of 5 NTU is just noticeable to the average person.

*Action Level (AL)* - the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

*Treatment Technique (TT)* - a required process intended to reduce the level of a contaminant in drinking water.

*Maximum Contaminant Level Goal, or MCLG* - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Contaminant Level, or MCL* - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Abbreviations:* NA – Not Applicable.

## WATER QUALITY RESULTS

| Radiological Contaminants         |      |   |  |            |                |  |
|-----------------------------------|------|---|--|------------|----------------|--|
| Contaminant / Unit of Measurement | MCLG | MCL   | Level Found  | Violation  | Date of Sample | Typical Source of Contamination  |
| Alpha emitters pCi/L              | 0    | 15  | <0.6   | No         | April 2015     | Erosion of natural deposits  |
| Combined Radium pCi/L             | 0    | 5   | <0.6   | No         | April 2015     | Erosion of natural deposits  |
| Inorganic Contaminants            |      |   |  |            |                |  |
| Contaminant / Unit of Measurement | MCLG | MCL   | Level Found / Range  | Exceedance | Date of Sample | Typical Source of Contamination  |
| Nitrates ppm                      | 10   | 10  | Range 0.21-0.33<br>Avg. 0.28   | No         | March-May 2017 | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Lead ppb                          | 0    | AL = 15                                     | <2(90 <sup>th</sup> percentile)<br>Range: ND - 12<br>Of the 30 samples collected none exceeded the AL.       | No         | September 2015 | Corrosion of household plumbing systems; Erosion of natural deposits                         |
| Copper ppm                        | 1.3  | AL=1.3                                      | 0.35(90 <sup>th</sup> percentile)<br>Range: ND to 0.424<br>Of the 30 samples collected none exceeded the AL. | No         | September 2015 | Corrosion of household plumbing systems; Erosion of natural deposits                         |
| Fluoride ppm                      | 4    | 4   | Average 0.44<br>Range <0.2 – 0.59  | No         | Monthly 2017   | Water additive which promotes strong teeth   |
| Barium ppm                        | 2    | 2   | 0.018  | No         | March 2017     | Erosion of natural deposits  |
| Microbiological Contaminants      |      |   |  |            |                |  |
| Contaminant / Unit of Measurement | MCLG | MCL   | Level Found / Range  | Violation  | Date of Sample | Typical Source of Contamination  |
| Turbidity / NTU                   | N/A  | 1.0 Max TT<br>0.3 in 95% of monthly samples | 0.02-0.12 (Range)<br>100 % <0.3  | No         | Daily 2017     | Soil Runoff  |
| Total Coliform Bacteria           | 0    | 1 positive monthly sample                   | 0  | No         | Monthly 2017   | Naturally present in the environment   |

| <b>Disinfection Byproducts</b>           |             |  |  |                  |   |   |
|--|-------------|--|--|------------------|---|---|
| <b>Contaminant / Unit of Measurement</b> | <b>MCLG</b> | <b>MCL</b>   | <b>Level Found / Range</b>                                     | <b>Violation</b> | <b>Date of Sample</b>                     | <b>Typical Source of Contamination</b>    |
| Chlorine ppm                             | 4           | 4  | Avg. 0.60<br>Range: 0.1 – 1.2                                  | No               | Monthly at bacti sample points            | Water additive used to control microbes   |
| HAA5s (Total Haloacetic Acids) ppb       | N/A         | 60   | Highest Qtr. Avg. 34<br>Range: 12 to 36                        | No               | Quarterly 2017                            | By-product of drinking water disinfection |
| TTHMs (Total Trihalomethanes) ppb        | N/A         | 80   | Highest Qtr. Avg. 125<br>Range: 31 to 140                      | No               | Quarterly 2017                            | By-product of drinking water disinfection |
| Total Organic Carbon (TOC) ppm           | N/A         | TT-TOC removal ratio greater than or equal to 1.00 | Lowest Quarterly Ave. Ratio:<br>1.00<br>Range:<br>1.00 to 1.75 | No               | Tested quarterly at raw and treated water | Naturally present in the environment      |

**Unregulated Contaminant Monitoring Rule (UCMR3)**

| <b>Contaminant / Unit of Measurement</b> | <b>MCLG</b> | <b>MCL</b> | <b>Average / Range</b>          | <b>Violation</b> | <b>Date of Sample</b> | <b>Typical Source of Contamination</b>  |
|--|-------------|------------|---------------------------------|------------------|-----------------------|---|
| Strontium ppb                            | NA          | NA         | 120                             | NA               | June 2014             | Naturally occurring element; used in steel production, as a catalyst, and as a lead scavenger                         |
| Vanadium ppb                             | NA          | NA         | Average: 0.95<br>Range: 0.9-1.0 | NA               | June 2014             | Naturally occurring element; commonly used in the production of other substances                                      |
| 1,4-Dioxane ppb                          | NA          | NA         | 0.10                            | NA               | June 2014             | Used in the manufacture and processing of paper, cotton, textile products, automotive coolant, cosmetics and shampoos |
| Chromium, Hexavalent ppb                 | NA          | NA         | 0.16                            | NA               | June 2014             | Discharge from steel and pulp mills; erosion of natural deposits  |

**UCMR3**

HCSA was enrolled in the UCMR3 program by the EPA for sampling of unregulated contaminants. Unregulated contaminants are those that don't yet have a drinking water standard set by USEPA. The purpose of monitoring for these contaminants is to help USEPA decide whether the contaminants should have a standard. This program was based off of the utility's population served, in which we were under the qualifying 10,000 served and we will no longer be continuing this sampling program unless we reach the qualifying population mark.

## **Water Quality Results**

We regularly monitor for various contaminants in the water supply to meet all regulatory requirements. The table lists only those contaminants that had some level of detection. Many other contaminants have been analyzed but were not present or were below the detection limits of the lab equipment.

Most of the results in the table are from testing done in 2017. However, the state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The Town of South Boston received the 2017 Excellence in Waterworks Operations and Performance Award from the Virginia Department of Health along with the 2015 Fluoridation Quality Award.

## **VIOLATION INFORMATION**

We are also pleased to report to you that there were no detections of total coliforms or fecal coliforms in the monthly samples collected during the calendar year 2017 and that the Authority did not receive any violations in the 2017 reporting year.

This Drinking Water Quality Report was prepared by William Samples, Superintendent of Water, Halifax County Service Authority, at 2529 Houghton Avenue, South Boston, VA 24592.